



NOTES:

- 1) COMPRESSOR UNIT MUST BE INSTALLED IN A ROOM ON A FLAT FLOOR
- 2) COMPRESSOR IS AN AIR COOLED UNIT - ROOM TEMPERATURE MUST NOT EXCEED 104° F
EXHAUST DUCTS OR VENTILATING FAN MUST BE INSTALLED IF ROOM TEMPERATURE EXCEEDS 104° F
- 3) PROVIDE ADEQUATE SPACE DURING INSTALLATION FOR NECESSARY MAINTENANCE AND REPAIRS
ALLOW A MINIMUM OF 20" ON EACH SIDE AND 24" FROM TOP OF UNIT FROM WALLS
- 4) CARE MUST BE TAKEN TO INSURE COMPRESSOR UNIT DOES NOT INTAKE HOT AIR OR DUST
- 5) REFER TO INSTRUCTION MANUAL FOR ELECTRIC WIRING DIAGRAM
- 6) SPEC IS SUBJECT TO CHANGE WITHOUT NOTICE

	OFB-3
HORSEPOWER	3
MAX. OPERATING PRESSURE (PSI)	120
AIR DELIVERY (CFM)	9.5
AIR OUTLET	3/4" NPT
OPERATING VOLTAGE	3 PHASE, 208-230V/460V, 60Hz
DIMENSIONS (INCHES)	44" x 25" x 25"
APPROX. WT. (LBS.)	180

PROPRIETARY AND CONFIDENTIAL
THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF ANEST IWATA. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF ANEST IWATA IS PROHIBITED.

UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN INCHES AND MILLIMETERS	DRAWN	NAME	DATE
INTERPRET GEOMETRIC TOLERANCING PER:	CHECKED	AMM	4/29/20
MATERIAL ASS'Y	ENG APPR.	AGH	4/30/20
PART NO.	MFG APPR.		
DO NOT SCALE DRAWING	Q.A.		
	COMMENTS:		

ANEST IWATA Air Engineering Inc.			
TITLE: OFB-3 OIL-FREE PISTON UNIT BASE MOUNT COMPRESSOR			
SIZE B	DWG. NO. OFB-3-R1	REV 1	
SCALE: 1:12		WEIGHT:	SHEET 1 OF 1