

	OFT-5(H)-FM-60
HORSEPOWER	5
OPERATING PRESSURE (PSI)	90-120
AIR DELIVERY (CFM)	13.6
CONTROL SYSTEM	MULTIPLE UNIT CONTROL AUTO/START STOP
NOISE LEVEL (dB A)	73
AIR OUTLET (BALL VALVE)	3/8" NPT
OPERATING VOLTAGE	3 PHASE, 208-230/460V, 60Hz
DIMENSIONS (L x W x H)	48" x 33" x 54"
APPROX. WT. (LBS.)	470

NOTE: HIGH PRESSURE SPECS AVAILABLE UPON REQUEST


1/4" NPT DRAIN VALVE
G 1/4", Ø8-10mm
AUTO DRAIN CONNECTION

3/8" NPT
DISCHARGE VALVE

- NOTES:**
- 1) COMPRESSOR UNIT MUST BE INSTALLED IN A ROOM ON A FLAT FLOOR
 - 2) COMPRESSOR IS AN AIR COOLED UNIT - ROOM TEMPERATURE MUST NOT EXCEED 104° F
EXHAUST DUCTS OR VENTILATING FAN MUST BE INSTALLED IF ROOM TEMPERATURE EXCEEDS 104° F
 - 3) PROVIDE ADEQUATE SPACE DURING INSTALLATION FOR NECESSARY MAINTENANCE AND REPAIRS
ALLOW A MINIMUM OF 20" ON EACH SIDE AND 24" FROM TOP OF UNIT FROM WALLS
 - 4) CARE MUST BE TAKEN TO INSURE COMPRESSOR UNIT DOES NOT INTAKE HOT AIR OR DUST
 - 5) REFER TO INSTRUCTION MANUAL FOR ELECTRIC WIRING DIAGRAM
 - 6) SPEC IS SUBJECT TO CHANGE WITHOUT NOTICE

PROPRIETARY AND CONFIDENTIAL
THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF ANEST IWATA. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF ANEST IWATA IS PROHIBITED.

MATERIAL
PART NO.
DO NOT SCALE DRAWING

	NAME	DATE	 ANEST IWATA Air Engineering Inc.
DRAWN	SDR	4/20/20	
CHECKED			
ENG APPR.			
MFG APPR.			
Q.A.			TITLE: OFT-5(H)-FM-60 OIL-FREE PISTON UNIT TANK MOUNT COMPRESSOR FILTER MEMBRANE DRYER
COMMENTS:			
SIZE	DWG. NO.	REV	
B	OFT-5(H)-FM-60-R1	1	
SCALE: 1:20 WEIGHT:		SHEET 1 OF 1	