SLT-10-80 HORSEPOWER 10 **OPERATING PRESSURE (PSI)** 85-115 29.7 AIR DELIVERY (CFM) D **CONTROL SYSTEM** MULTIPLE UNIT CONTROL - AUTO START/STOP NOISE LEVEL (dB A) 75 3/4" NPT AIR OUTLET (BALL VALVE) **OPERATING VOLTAGE** 3 PHASE, 208-230V/460V, 60Hz 00000 DIMENSIONS (LxWxH) 64" x 29" x 49" APPROX. WT. (LBS.) 580 29in 64in 1627mm 739mm С 3/4" NPT DISCHARGE VALVE-257mm 00000 656mm _26in 1/4" NPT DRAIN VALVE G 1/4", \emptyset 8-10mm AUTO DRAIN CONNECTION ANEST UNLESS OTHERWISE SPECIFIED: NAME DATE ANEST IWATA Air Engineering Inc. AGH 4/7/20 DRAWN DIMENSIONS ARE SHOWN IN NCHES AND MILLIMETERS 4/8/20 TITLE: AMM CHECKED SLT-10-80 ENG APPR. NOTES:

1) COMPRESSOR UNIT MUST BE INSTALLED IN A ROOM ON A FLAT FLOOR

2) COMPRESSOR IS AN AIR COOLED UNIT - ROOM TEMPERATURE MUST NOT EXCEED 104° F OIL FREE SCROLL UNIT MFG APPR. TANK MOUNT COMPRESSOR EXHAUST DUCTS OR VENTILATING FAN MUST BE INSTALLED IF ROOM TEMPERATURE EXCEEDS 104° F
3) PROVIDE ADEQUATE SPACE DURING INSTALLATION FOR NECESSARY MAINTENANCE AND REPAIRS PROPRIETARY AND CONFIDENTIAL COMMENTS: THE INFORMATION CONTAINED IN THIS MATERIAL SIZE DWG. NO. REV ASS'Y DRAWING IS THE SOLE PROPERTY OF ALLOW A MINIMUM OF 20" ON EACH SIDE AND 24" FROM TOP OF UNIT FROM WALLS SLT-10-80-R2 ANEST IWATA. ANY 4) CARE MUST BE TAKEN TO INSURE COMPRESSOR UNIT DOES NOT INTAKE HOT AIR OR DUST 5) REFER TO INSTRUCTION MANUAL FOR ELECTRIC WIRING DIAGRAM REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF 6) SPEC IS SUBJECT TO CHANGE WITHOUT NOTICE ANEST IWATA IS SCALE: 1:15 WEIGHT: SHEET 1 OF 3 DO NOT SCALE DRAWING

3